


# Town of Littleton Finance Report

Ending Date: 12/31/2016

General Funds Budgeted	<u>\$ 604,875.00</u>	
Collected Year to Date	<u>\$ 264,982.98</u>	<u>43 %</u>
General Fund Expenditures Year to Date	<u>\$ 249,919.67</u>	<u>41 %</u>
Water/Sewer Funds Budgeted	<u>\$ 510,680.00</u>	
Collected Year to Date	<u>\$ 181,519.51</u>	<u>35 %</u>
Water/Sewer Fund Expenditures Year to Date	<u>\$ 181,877.14</u>	<u>35 %</u>

Submitted to Record 01/05/2017



Donald J. Spigini

# HALIFAX COUNTY CENTRAL COMMUNICATIONS CENTER

## Number Of Calls Report by Complaint

Jurisdiction: HALIFAX

First Date: 12/01/2016

Last Date: 12/31/2016

Complaint		Number
911 ABAND	ABANDONED 911 CALL	1
911 OPEN LIN	911 OPEN LINE	1
ABAND VEH	ABANDONED VEHICLE	2
ALARM-BURG	ALARM - BURGLAR	3
ANIMAL CALL	ANIMAL CALL	1
ARMED SUBJ	SUBJ CARRYING A WEAPON	1
B&E VEH	BREAKING & ENTERING OF VEH	2
CUSTODY	CHILD/ADULT CUSTODY MATTERS	1
DISABLED VEH	DISABLED VEHICLE	1
DISPUTE	DISPUTE	1
DOMESTIC	DOMESTIC DISPUTE	1
DUI	INTOXICATED DRIVER	1
ESCORT	ESCORT	1
FOLLOWUP	FOLLOWUP INVESTIGATION	2
FOOT PATROL	FOOT PATROL	10
HIT&RUN NOPI	HIT AND RUN NO PI	1
INTOX PEDEST	INTOXICATED PEDESTRIAN	1
LARCENY	LARCENY REPORTED	1
PROPERTY	LOST/FOUND PROPERTY	1
SERVE PAPERS	SERVING PAPERS	3
SHOTS FIRED	SHOTS FIRED	1
SIGNS	SIGNS DOWN	2
SSR	PATROL OF RESIDENCE OR BUSINESS	1
SUSP ACTIVITY	SUSP ACTIVITY	2
SUSP PERS	SUSPICIOUS PERSON	1
SUSP VEHIC	SUSPICIOUS VEHICLE	3
TEST CALL	TEST CALL	1
TRAFFIC SIGS	MALFUNCTIONS, POWER OUTAGES, E	1
TRAFFIC STOP	GENERAL TRAFFIC STOP	47
WRECK NOPI	MOTOR VEHICLE ACCIDENT NO PERS	1
<b>Report Total:</b>		<b>96</b>

DCI/DMM

350

POTABLE WATER REPORT FOR MONTH OF JANUARY 2017  
READINGS ARE FROM NOVEMBER 15<sup>TH</sup> THRU DECEMBER 15<sup>TH</sup>  
TOTAL AMOUNT PURCHASED 2.274 MILLION  
TOTAL AMOUNT SOLD 1.404 MILLION

TOTAL USED AT WWTP 158,000  
TOTAL USED FOR LVFD.000  
TOTAL USED AT TOWN PARK 000  
TOTAL USED AT POLICE STA. 3,000  
TOTAL USED AT TOWN HALL 3,000  
TOTAL USED AT LIBRARY 3,000

TOTAL USED FOR FLUSHING OF HYDRANT 270,000  
TOTAL AMOUNT UNACCOUNTED FOR 438,000 GALLONS

2 BACTERIAL TEST RESULTS WERE NEGATIVE

COPY OF STATEMENT FROM HALIFAX CO IS ATTACHED  
THE READING FROM HALIFAX CO. IS FOR 33 DAYS  
THE READINGS FOR THE TOWN ARE FOR 30 DAYS

TOWN OF LITTLETON, N.C.  
WASTEWATER SYSTEM OPERATION  
MONTHLY REPORT

---

MONTH JAN 2017

PERIOD OF MEASUREMENT: Nov 1, 2016 TO Nov 30, 2016: 30 DAYS

NPDES PERMITTED TREATMENT CAPACITY 280,000 G P D

TOTAL VOLUME TREATED THIS PERIOD: 1.5 M G D

AVERAGE DAILY FLOW 50,000 G P D

MEASURED RAINFALL DURING PERIOD OF RECORD 2 2/10 INCHES

MAXIMUM FLOW READINGS DURING PERIOD OF RECORD

Q-HIGH 72,000 GPD Q LOW 41,000 GPD

EFFLUENT QUALITY

BOD5: HIGH 11.8 MG/L LOW 6.25 MG/L AVG 9.0 MG/L LIMITS 30 MG/L

NH3/N HIGH 8.48 MG/L LOW <1 MG/L AVG 4.0 MG/L LIMITS 4.0 MG/L

TSS HIGH 16.8 MG/L LOW 4.40 MG/L AVG 10.6 MG/L LIMITS 30 MG/L

PO4 HIGH 3.3 MG/L LOW 2.0 MG/L AVG 2.8 MG/L LIMITS N/A MG/L

CL2 HIGH 34 UG/L LOW 30 UG/L AVG 32 UG/L LIMITS 50 UG/L

EFFLUENT QUALITY IS () IN COMPLIANCE () NOT IN COMPLIANCE  
WITH PERMIT

GENERAL COMMENTS

- 1 - no sewer overflows
- 2 - no inspections
- 3 - no violations

SUBMITTED Jan 5, 2017  
DATE

BY David K. [Signature]  
PLANT OPERATOR