


Town of Littleton Finance Report

Ending Date: 07/31/2017

General Funds Budgeted	<u>\$ 649,075.00</u>	
Collected Year to Date	<u>\$ 14,383.82</u>	<u>2 %</u>
General Fund Expenditures Year to Date	<u>\$ 16,592.18</u>	<u>3 %</u>
Water/Sewer Funds Budgeted	<u>\$ 494,893.00</u>	
Collected Year to Date	<u>\$ 29,287.69</u>	<u>6 %</u>
Water/Sewer Fund Expenditures Year to Date	<u>\$ 9,065.43</u>	<u>2 %</u>

Submitted to Record 08/07/2017



Donald J. Spingarn

HALIFAX COUNTY CENTRAL COMMUNICATIONS CENTER

Number Of Calls Report by Department - Complaint

Jurisdiction: HALIFAX

First Date: 07/01/2017

Last Date: 07/30/2017

350

Department	Complaint	Number
	ANIMAL CALL	2
	ASSISTANCE	3
	DISABLED VEH	1
	EMS CALL	1
	FOLLOWUP	2
	FOOT PATROL	8
	HIT&RUN NOPI	1
	LARCENY	1
	MISC. VEHICL	2
	MISSING PERS	1
	ORDINANCE VI	1
	PROPERTY	1
	SUSP PERS	1
	TRAFFIC STOP	44
	WRECK NOPI	3
	ANIMAL CALL	2
	ASSISTANCE, GEN. MOTORIST, ETC	3
	DISABLED VEHICLE	1
	EMS CALL	1
	FOLLOWUP INVESTIGATION	2
	FOOT PATROL	8
	HIT AND RUN NO PI	1
	LARCENY REPORTED	1
	FOURWHEELERS, GO-CARTS VIOLATI	2
	MISSING PERSON	1
	ORDINANCE VIOLATION	1
	LOST/FOUND PROPERTY	1
	SUSPICIOUS PERSON	1
	GENERAL TRAFFIC STOP	44
	MOTOR VEHICLE ACCIDENT NO PERS	3
	Group Total:	72
	Report Total:	72

DCI/DMV NOT FOR PUBLIC/BLET USE

POTABLE WATER REPORT FOR MONTH OF AUGUST 2017

METER READINGS ARE FROM JUNE 15TH THRU JULY 15TH

TOTAL AMOUNT PURCHASED 2,224,000

TOTAL AMOUNT SOLD 1,570,000

TOTAL USED AT WWTP 191,000

TOTAL USED FOR LVFD 0,000

TOTAL USED AT TOWN PARK 000

TOTAL USED AT POLICE STA. 3000

TOTAL USED AT TOWN HALL 3000

TOTAL USED AT LIBRARY 3000

TOTAL USED FOR FLUSHING OF HYDRANTS 184,000

TOTAL AMOUNT UNACCOUNTED FOR 270,000 GALLONS

THE BILLING CYCLE FROM HALIFAX CO. WAS FOR 31 DAYS

2 BACTERIAL TEST RESULTS WERE NEGATIVE

TOWN OF LITTLETON, N.C.
WASTEWATER SYSTEM OPERATION
MONTHLY REPORT

MONTH Aug 2017

PERIOD OF MEASUREMENT: June 1, 2017 TO June 30, 2017: 30 DAYS

NPDES PERMITTED TREATMENT CAPACITY 280,000 G P D

TOTAL VOLUME TREATED THIS PERIOD: 1.86 M G D

AVERAGE DAILY FLOW 62,000 G P D

MEASURED RAINFALL DURING PERIOD OF RECORD 2 3/10 INCHES

MAXIMUM FLOW READINGS DURING PERIOD OF RECORD

Q-HIGH 129,000 GPD Q LOW 43,000 GPD

EFFLUENT QUALITY

BOD5: HIGH 7.07 MG/L LOW 2.27 MG/L AVG 5.0 MG/L LIMITS 30 MG/L

NH3/N HIGH 4.8 MG/L LOW <1 MG/L AVG 1.0 MG/L LIMITS 2.0 MG/L

TSS HIGH 413 MG/L LOW 232 MG/L AVG 310 MG/L LIMITS 30 MG/L

PO4 HIGH 3.5 MG/L LOW 1.7 MG/L AVG 2.6 MG/L LIMITS 0.5 MG/L

CL2 HIGH 34 UG/L LOW 30 UG/L AVG 32 UG/L LIMITS 50 UG/L

EFFLUENT QUALITY IS () IN COMPLIANCE () NOT IN COMPLIANCE
WITH PERMIT

GENERAL COMMENTS

1. no Sewer overflows
2. no violations
3. Treatment Plant was inspected by Ms. Shannon Bass with a favorable report.

SUBMITTED Aug 7, 2017
DATE

BY 
PLANT OPERATOR