


Town of Littleton Finance Report

Ending Date: 01/31/2018

General Funds Budgeted	<u>\$ 649,075.00</u>		
Collected Year to Date	<u>\$ 306,115.43</u>	<u>47</u>	%
General Fund Expenditures Year to Date	<u>\$ 311,808.73</u>	<u>48</u>	%
Water/Sewer Funds Budgeted	<u>\$ 494,893.00</u>		
Collected Year to Date	<u>\$ 232,212.75</u>	<u>47</u>	%
Water/Sewer Fund Expenditures Year to Date	<u>\$ 223,401.03</u>	<u>45</u>	%

Submitted to Record 02/07/2018



HALIFAX COUNTY CENTRAL COMMUNICATIONS CENTER

Number Of Calls Report by Patrol - Complaint

Jurisdiction: HALIFAX

First Date: 01/01/2018

Last Date: 01/30/2018

Patrol	Complaint	Number	
ETPD	911 OPEN LIN	911 OPEN LINE	1
	ALARM-BURG	ALARM - BURGLAR	3
	ASSIST.OFFIC	OFFICER REQUESTING ASSIST - LIFE	1
	ASSISTANCE	ASSISTANCE, GEN. MOTORIST, ETC	2
	B&E OLD	BREAKING AND ENTERING HAPPENED	1
	DOMESTIC	DOMESTIC DISPUTE	1
	ESCORT	ESCORT	2
	FOLLOWUP	FOLLOWUP INVESTIGATION	1
	FOOT PATROL	FOOT PATROL	22
	LARCENY	LARCENY REPORTED	1
	LOGGED VEH	LOGGED VEHICLES	2
	ORDINANCE VI	ORDINANCE VIOLATION	1
	SIGNS	SIGNS DOWN	1
	SUSP VEHIC	SUSPICIOUS VEHICLE	2
	TRAFFIC STOP	GENERAL TRAFFIC STOP	35
	WRECK NOPI	MOTOR VEHICLE ACCIDENT NO PERS	1
		Group Total:	77
		Report Total:	77

DCI/DMV NOT FOR PUBLIC/BLET USE

TOWN OF LITTLETON, N.C.
WASTEWATER SYSTEM OPERATION
MONTHLY REPORT

MONTH Feb 2018

PERIOD OF MEASUREMENT: Dec 1, 2018 TO Dec 31, 2018 : 31 DAYS

NPDES PERMITTED TREATMENT CAPACITY 280,000 G P D

TOTAL VOLUME TREATED THIS PERIOD: 1.736 M G D

AVERAGE DAILY FLOW 56,000 G P D

MEASURED RAINFALL DURING PERIOD OF RECORD 1.6 INCHES

MAXIMUM FLOW READINGS DURING PERIOD OF RECORD
Q-HIGH 183,000 GPD Q LOW 31,000 GPD

EFFLUENT QUALITY

BOD5: HIGH 2.08 MG/L LOW <2 MG/L AVG 2.02 MG/L LIMITS 30 MG/L

NH3/N HIGH 5.5 MG/L LOW <1 MG/L AVG 3.34 MG/L LIMITS 40 MG/L

TSS HIGH 31.0 MG/L LOW 5.4 MG/L AVG 14.3 MG/L LIMITS 30 MG/L

PO4 HIGH 1.5 MG/L LOW 0.2 MG/L AVG 0.83 MG/L LIMITS 0.8 MG/L

CL2 HIGH 35 UG/L LOW 31 UG/L AVG 33.1 UG/L LIMITS 50 UG/L

EFFLUENT QUALITY IS IN COMPLIANCE NOT IN COMPLIANCE
WITH PERMIT

GENERAL COMMENTS

- 1- No Inspections
- 2- no violations
- 3- no Sewer overflows

SUBMITTED Feb 7, 2018
DATE

BY [Signature]
PLANT OPERATOR

POTABLE WATER REPORT FOR MONTH OF FEBRUARY 2018
READINGS ARE FROM DECEMBER 15TH THRU JANUARY 15TH
TOTAL AMOUNT PURCHASED 3.437 MILLION
TOTAL AMOUNT SOLD 2.047 MILLION

TOTAL USED AT WWTP 194,000
TOTAL USED FOR LVFD. 0,000
TOTAL USED AT TOWN PARK 000
TOTAL USED AT POLICE STA. 3,000
TOTAL USED AT TOWN HALL 3,000
TOTAL USED AT LIBRARY 3,000

TOTAL USED FOR FLUSHING OF HYDRANT 310,000
TOTAL AMOUNT UNACCOUNTED FOR 877,000 GALLONS

2 BACTERIAL TEST RESULTS WERE NEGATIVE

THE READING FROM HALIFAX CO. IS FOR 35 DAYS
THE READINGS FOR THE TOWN ARE FOR 30 DAYS