

# HALIFAX COUNTY CENTRAL COMMUNICATIONS CENTER

## Number Of Calls Report by Department - Complaint (All Units)

Jurisdiction: HALIFAX

First Date: 12/01/2017

Last Date: 12/31/2017

350

Department	Complaint	Number	
0020	ABAND VEH	ABANDONED VEHICLE	1
	ALARM-BURG	ALARM - BURGLAR	2
	ANIMAL CALL	ANIMAL CALL	3
	ASSAULT	ASSAULT	1
	ASSIST.OFFIC	OFFICER REQUESTING ASSIST - LIFE	1
	ASSISTANCE	ASSISTANCE, GEN. MOTORIST, ETC	2
	B&E OLD	BREAKING AND ENTERING HAPPENED	1
	B&E VEH	BREAKING & ENTERING OF VEH	2
	C&R	CARELESS AND RECKLESS DRIVER	1
	DEBRIS	DEBRIS	1
	DISABLED VEH	DISABLED VEHICLE	1
	DISPUTE	DISPUTE	1
	DISTURBANCE	NOISE, LOUD MUSIC, LOUD DOGS, ET	2
	DOMESTIC	DOMESTIC DISPUTE	3
	DUI	INTOXICATED DRIVER	1
	ESCORT	ESCORT	2
	FIRE-FATALIT	FIRE-FATALITY	1
	FOLLOWUP	FOLLOWUP INVESTIGATION	3
	FOOT PATROL	FOOT PATROL	22
	FRAUD	FRAUD	1
	HIT&RUN NOPI	HIT AND RUN NO PI	1
	ID THEFT	IDENTITY THEFT	1
	LARCENY	LARCENY REPORTED	2
	MENTAL SUBJ	MENTAL SUBJECT	1
	SEX OFFENSES	SEX OFFENSES	1
	SHOTS FIRED	SHOTS FIRED	1
	SPECIAL ASSG	SPECIAL ASSIGNMENT	2
	THREATS	THREATS, COMMUNICATING	2
	TRAFFIC STOP	GENERAL TRAFFIC STOP	43
	TRESPASSER	TRESPASSER REPORTED	2
	UTILITIES	WATER, SEWER, ELECTRIC PROBLEM	1
	WRECK,NORI	MOTOR VEHICLE ACCIDENT NO PERS	1

Group Total: 110

Report Total: 110

A call with multiple Departments assigned will be counted in the group total for each of these Departments, therefore such calls will be counted more than once. For this reason, the total number of calls may not equal the sum of the group totals


# Town of Littleton Finance Report

Ending Date: 12/31/2017

General Funds Budgeted	<u>\$ 649,075.00</u>	
Collected Year to Date	<u>\$ 271,539.09</u>	<u>42 %</u>
General Fund Expenditures Year to Date	<u>\$ 277,076.72</u>	<u>43 %</u>

Water/Sewer Funds Budgeted	<u>\$ 494,893.00</u>	
Collected Year to Date	<u>\$ 200,243.87</u>	<u>40 %</u>
Water/Sewer Fund Expenditures Year to Date	<u>\$ 199,306.09</u>	<u>40 %</u>

Submitted to Record 01/03/2018



---

POTABLE WATER REPORT FOR MONTH OF JANUARY 2018  
READINGS ARE FROM NOVEMBER 15<sup>TH</sup> THRU DECEMBER 15<sup>TH</sup>  
TOTAL AMOUNT PURCHASED 1.827 MILLION  
TOTAL AMOUNT SOLD 1.279 MILLION

TOTAL USED AT WWTP 186,000  
TOTAL USED FOR LVFD. 190,000  
TOTAL USED AT TOWN PARK 000  
TOTAL USED AT POLICE STA. 3,000  
TOTAL USED AT TOWN HALL 3,000  
TOTAL USED AT LIBRARY 3,000

TOTAL USED FOR FLUSHING OF HYDRANT 140,000  
TOTAL AMOUNT UNACCOUNTED FOR 23,000 GALLONS

2 BACTERIAL TEST RESULTS WERE NEGATIVE

THE READING FROM HALIFAX CO. IS FOR 29 DAYS  
THE READINGS FOR THE TOWN ARE FOR 30 DAYS

TOWN OF LITTLETON, N.C.  
WASTEWATER SYSTEM OPERATION  
MONTHLY REPORT

---

MONTH January 2018

PERIOD OF MEASUREMENT: Nov 1, 2017 TO Nov 30, 2017 : 30 DAYS

NPDES PERMITTED TREATMENT CAPACITY 280,000 G P D

TOTAL VOLUME TREATED THIS PERIOD: 1.26 M G D

AVERAGE DAILY FLOW 42,000 G P D

MEASURED RAINFALL DURING PERIOD OF RECORD 2.0 INCHES

MAXIMUM FLOW READINGS DURING PERIOD OF RECORD

Q-HIGH 86,000 GPD Q LOW 28,000 GPD

EFFLUENT QUALITY

BOD5: HIGH 36.0 MG/L LOW 1.0 MG/L AVG 9.75 MG/L LIMITS 30 MG/L

NH3/N HIGH 7.9 MG/L LOW 0 MG/L AVG 5.4 MG/L LIMITS 4.0 MG/L

TSS HIGH 29.4 MG/L LOW 100 MG/L AVG 21.5 MG/L LIMITS 30 MG/L

PO4 HIGH 3.3 MG/L LOW 1.9 MG/L AVG 2.6 MG/L LIMITS M/A MG/L

CL2 HIGH 34 UG/L LOW 30 UG/L AVG 32 UG/L LIMITS 50 UG/L

EFFLUENT QUALITY IS () IN COMPLIANCE ( ) NOT IN COMPLIANCE  
WITH PERMIT

GENERAL COMMENTS

- 1 - no violations
- 2 - no inspections
- 3 - no sewer overflow

SUBMITTED

Jan 3, 2018  
DATE

BY

[Signature]  
PLANT OPERATOR